

RESOLUTION NO. 2821

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF BONNEY LAKE, PIERCE COUNTY, WASHINGTON, AUTHORIZING THE PURCHASE OF A SPARE PUMP FOR LIFT STATION 19 (WILLOWBROOK) FROM GRANICH ENGINEERED PRODUCTS, INC.

WHEREAS, the City sewer utility inherited Lift Station 19 as part of the annexation of the Willowbrook sub-division. Lift Station 19 is a regional lift station receiving flow from other lift stations before pumping to Lift Station 17 and as such it is essential that it continues to operate without interruption; and


WHEREAS, this lift station was built by Pierce County standards and its pumps are original to the Lift Station and have never been serviced; and

WHEREAS, the City requested and received quotes from 2 vendors for a spare pump to allow Sewer Utility staff to pull each original pump for servicing and repair as necessary ; and

WHEREAS, the City approved this purchase as part of the 2020 budget;


NOW, THEREFORE, BE IT RESOLVED that the City Council of the City of Bonney Lake, Washington, does hereby authorize the Mayor to approve the purchase of a Spare Pump for Lift Station 19 in the amount of \$36,062.44 from Granich Engineered Products, Inc.

PASSED by the City Council this 24th day of March, 2020.



Neil Johnson, Jr., Mayor

AUTHENTICATED:


Harwood T. Edvalson, City Clerk

City of Bonney Lake, Washington
City Council Agenda Bill (AB)

Department/Staff Contact: Public Works / Todd Bright, Assistant Superintendent	Meeting/Workshop Date: 24 March 2020	Agenda Bill Number: AB20-33
Agenda Item Type: Resolution	Ordinance/Resolution Number: 2821	Councilmember Sponsor:

Agenda Subject: Authorize the Purchase of A Spare Pump at Lift Station 19 (Willowbrook) from Granich Engineered Products, Inc.

Full Title/Motion: A Resolution Of The City Council Of The City Of Bonney Lake, Pierce County, Washington, Authorizing The Purchase Of A Spare Pump At Lift Station 19 (Willowbrook) From Granich Engineered Products, Inc.

Administrative Recommendation: Approve

Background Summary: Lift Station 19 was inherited from Pierce County when Willowbrook was annexed into the City. Lift Station 19 has two, 75 hp Fairbanks Morse pumps that are original to the lift station (over 15 years old) and have never been rebuilt. In order to guarantee continued and uninterrupted flow through this regional lift station, the pumps need to be rotated out for servicing. In order to do that, a spare pump is needed. Funds were included as part of the Sewer Utility's 2020 budget to purchase a spare 75 hp Fairbanks Morse pump to allow the Utility to pull each pump for servicing.

Attachments: Resolution 2821, Quote

BUDGET INFORMATION

Budget Amount	Current Balance	Required Expenditure	Budget Balance	Fund Source
\$40,000	\$40,000	\$36,062.44	\$3,936.56	<input type="checkbox"/> General <input checked="" type="checkbox"/> Utilities <input type="checkbox"/> Other

Budget Explanation: Sewer: 401.000.035.594.35.64.03-Capital Outlay.

Revenue Source: Rates

COMMITTEE, BOARD & COMMISSION REVIEW

Council Committee Review:	<i>Approvals:</i>	Yes	No
Date:	Chair/Councilmember Dan Swatman	<input type="checkbox"/>	<input type="checkbox"/>
	Councilmember Michelle Keith	<input type="checkbox"/>	<input type="checkbox"/>
	Councilmember Tom Watson	<input type="checkbox"/>	<input type="checkbox"/>
Forward to:	Consent Agenda:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

Commission/Board Review:

Hearing Examiner Review:

COUNCIL ACTION

Workshop Date(s):	Public Hearing Date(s):
Meeting Date(s):	Tabled to Date:

APPROVALS

Director: <i>Ryan Johnstone, Interim Public Services Director</i>	Mayor: <i>Neil Johnson, Jr.</i>	Date Reviewed by City Attorney: (if applicable)
---	---	---

Exhibit A



Granich Engineered Products, Inc
1313 S 96th Street.
Seattle, WA 98108
Phone: 866-859-2940
Fax: 206-315-2939
Website: www.granich.com

Quote-Rev1

To:	City of Bonney Lake Attn: Lance Johnson	Email:	johnsonl@ci.bonny-lake.wa.us
From:	Ken Hogan	Phone:	253-261-1129
Date:	02/12/2020	Date:	02/12/2020
Re:	Fairbanks Morse S/N 76862-1 replacement pump	Pages:	1

We are pleased to offer the following equipment for your consideration.

(1)- Fairbanks Morse model 4" D5434MV, submersible non clog sewage pump, standard fitted construction, SS wear rings, quick disconnect guide rail system, 75 HP, 460 volt, 3-phase, UL labeled explosion proof motor, coal tar epoxy coating, 80 foot long power cord. Built to match existing s/n 76862-1

Price: \$31,594.00 Net Each
Freight: \$1400.00
Tax at 9.3%: \$3068.44

Total: \$36,062.44

Prices are F.O.B. factory. Sales tax is not included. Terms: Net 30 days on approved credit. This quote is based on GEP's standard terms & conditions of sale. Please allow approx. 12 weeks for shipment. Please call me if you have any questions or need additional information.

Regards,

Ken Hogan

Ken Hogan
Granich Engineered Products, Inc

GRANICH ENGINEERED PRODUCTS, INC